



AS BUILT

- 4-27-05 REV. PER DCN-H-1-11219 SHT01-01-04 CAB G.C. [Signature]
- NOTES:**
1. DUCT SHALL BE DESIGNED FOR MINIMUM 3.5" SP
 2. DUCT GAUGE REINFORCEMENT AND HANGERS SHALL BE DETERMINED PER SHADING PLANS DUCT CONSTRUCTION SYSTEMS
 3. ALL OUTSIDE DUCT SHALL BE WELDED CONSTRUCTION
 4. ALL DUCTS INSIDE SHALL BE STANDARD SEAM CONSTRUCTION
 5. MAXIMUM SPACING OF HANGERS PER SMACNA
 6. REFER TO DWG H-1-11219 FOR FAN, REGISTER, AND DIFFUSER SPECIFICATIONS
 7. NEW DUCT AND SUPPORTS SHALL BE PAINTED AS PER EXISTING DUCTS AND SUPPORTS
 8. ALL DUCT ELBOWS TO BE PROVIDED WITH TURNING VALVES
 9. EXPANSION ANGLE SHALL NOT BE GREATER THAN 15°
 10. PROVIDE EXPANSION JOINT AT DISCHARGE OF FAN UNIT

PROJECT COMPLETE		DATE: 11/15/99																
1. CHECKED FOR AS-BUILT		DATE: 11/15/99																
<table border="1"> <tr> <th>REV.</th> <th>DATE</th> <th>DESCRIPTION</th> <th>BY</th> <th>APP'D BY</th> <th>FOR</th> <th>DATE</th> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>				REV.	DATE	DESCRIPTION	BY	APP'D BY	FOR	DATE								
REV.	DATE	DESCRIPTION	BY	APP'D BY	FOR	DATE												
<table border="1"> <tr> <th colspan="2">CLASSIFICATION</th> <th colspan="2">CLASSIFIED BY</th> </tr> <tr> <td colspan="2">NONE</td> <td colspan="2">[Signature]</td> </tr> <tr> <td colspan="2">DATE: 1-6-59</td> <td colspan="2">DATE: 11/15/99</td> </tr> </table>				CLASSIFICATION		CLASSIFIED BY		NONE		[Signature]		DATE: 1-6-59		DATE: 11/15/99				
CLASSIFICATION		CLASSIFIED BY																
NONE		[Signature]																
DATE: 1-6-59		DATE: 11/15/99																
<table border="1"> <tr> <th>DWG. NO.</th> <th>SCALE</th> <th>DATE</th> <th>BY</th> <th>DATE</th> </tr> <tr> <td>H-1-11219</td> <td>NONE</td> <td>11/15/99</td> <td>[Signature]</td> <td>12-21-99</td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>				DWG. NO.	SCALE	DATE	BY	DATE	H-1-11219	NONE	11/15/99	[Signature]	12-21-99					
DWG. NO.	SCALE	DATE	BY	DATE														
H-1-11219	NONE	11/15/99	[Signature]	12-21-99														
<table border="1"> <tr> <th colspan="2">DES. ENG. MICRODOT UNIT</th> <th colspan="2">APPROVALS</th> </tr> <tr> <td colspan="2">INST. NO. 10486</td> <td colspan="2">DATE: 12-21-99</td> </tr> <tr> <td colspan="2">PROJECT NO. 0780</td> <td colspan="2"> </td> </tr> </table>				DES. ENG. MICRODOT UNIT		APPROVALS		INST. NO. 10486		DATE: 12-21-99		PROJECT NO. 0780						
DES. ENG. MICRODOT UNIT		APPROVALS																
INST. NO. 10486		DATE: 12-21-99																
PROJECT NO. 0780																		
<p>U. S. ATOMIC ENERGY COMMISSION HANFORD ATOMIC PRODUCTS OPERATION GENERAL ELECTRIC</p> <p>VENTILATION PLAN, SECTIONS & DETAILS VALVE PIT, TUNNELS, PROCESS AREA & ACCUMULATOR ROOM IMPROVED VENT. BLDGS. 105-B, D&F</p>																		
DWG. NO. H-1-11219		DRAWING TITLE: 8900																

DWG. NO.	DESCRIPTION	DATE	BY
H-1-11207	VENT. BLDG. 105-B, D&F SUPPLY & EXHAUST	11/15/99	[Signature]
H-1-11202	VENT. EXH. DUCT - PLAN & SECTIONS	11/15/99	[Signature]
H-1-11210	PROCESS WATER PIPING - VALVE PIT TO RISER -	11/15/99	[Signature]
H-1-11215	SECS. 105-B, D, & F VENTILATION SUPPLY EXHAUST	11/15/99	[Signature]
H-1-11219	PIPE TUNNELS FOR MAIN PUMP HOUSE 105-B TO	11/15/99	[Signature]
H-1-11211	BLDG. 105-B, D, & F VENTILATION SUPPLY EXHAUST	11/15/99	[Signature]
H-1-11214	STEEL FRAMING - MISC. DETAILS	11/15/99	[Signature]

THIS DWG. MODIFIES: H-1-11207, H-1-11202, H-1-11210, H-1-11215, H-1-11219, H-1-11211, H-1-11214