



SECTIONAL ELEVATION

PLAN VIEW IN SECTION SECTION "A-A"

H-3-20244

SHEET	REV.
2	2

NOTES:

- (a) WINDOW LINERS WITH HOUSINGS COMPLETE WITH GLASS ARE IDENTIFIED AS EPN 677-1  
(b) WINDOW LINERS WITH HOUSINGS FILLED WITH DENSE CONCRETE AGGREGATE HAVE A SUFFIX "A" SUCH AS EPN 677-1A
- FOR REVIBRATION REQUIREMENTS THAT WILL EFFECT FLUID LOADS ON FRAMES DURING CONCRETE PLACEMENT SEE REF #2.
- WHERE WINDOW (GLASS) IS NOT INSTALLED THE HOUSING SHALL BE FILLED WITH DENSE AGGREGATE OF THE MATERIAL AND GRADING AS SPECIFIED FOR HIGH DENSITY CONCRETE, BUT WITHOUT CEMENT AS PER REF #2
- THIS DRAWING FOR CONTRACTOR DESIGN AND INSTALLATION. SEE REF #2 FOR ADDITIONAL REQUIREMENTS

NO.	DESCRIPTION	REV. BY	DATE	APP'D BY	FOR	DATE
1	NOTES-REVISED	2479	10-5-62	HELL		
2	CHECKED FOR AS-BUILTS					
3	DELETED NOTES, ZN, B, E-2					
4	ADDED NOTE, ZN, A-6					

CHECK PRINT	COMMIT PRINT	APPROVED FOR CONST.	BY	FOR	DATE	REV.	
ISSUE NO.	DATE	ISSUE NO.	DATE	APPROVED FOR PURCHASE	BY	FOR	DATE
1st	5/27/62	3	7/10/62				
SCALE NONE		APPROVED FOR DESIGN					
DRAWN	DATE	BY	FOR	DATE			
H. D. Wilson	4/26/62						
CHECKED	DATE	BY	FOR	DATE			
R. W. Kelley	4/26/62	H. C. Kellum	CE#1	8-10-62			
PROJECT	ISSUE NO.	CLASSIFICATION					
CA-916	12479	NONE					
DATE	CLASSIFIED BY						
5/27/62	R. W. Kelley						

U. S. ATOMIC ENERGY COMMISSION	
HANFORD ATOMIC PRODUCTS OPERATION	
GENERAL ELECTRIC	
VIEWING WINDOW	
HOT METALLURGICAL CELLS	
FUELS RECYCLE PILOT PLANT	
BLDG. NO.	INDEX NO.
324	5001
DWG. NO.	SHEET NO.
H-3-20244	2