

**REQUEST FOR PROPOSAL (RFP) AMENDMENT**

<b>RFP NO.</b> 368477	<b>RFP DATE</b> 08/30/2023	<b>AMENDMENT NO.</b> 02	<b>AMENDMENT DATE</b> 09/18/2023
<b>ISSUED BY AND RETURN TO:</b> Central Plateau Cleanup Company P.O. Box 1600 Richland, WA 99352 Attn: Andrea Riste 509/373-7141 (tele) andrea_d_riste@rl.gov (e-mail) MSIN: A7-05		<b>DUE DATE</b> This amendment does not change the date by which offers are due unless a date and time is inserted below.	
		<b>DATE</b>	<b>TIME</b>

**DESCRIPTION OF AMENDMENT**

**The purpose of this RFP amendment is to:**

- 1) Transmit answers to FINAL offeror questions (below).
- 2) Transmit revised Statement of Work 09182023 (attached).
- 3) Transmit Revised Pricing Sheet 09182023 (attached)

**All other terms and conditions of this RFP remain unchanged.**

Except as provided herein, all terms and conditions of the Request for Proposal remain unchanged and in full force and effect.

**II. ACKNOWLEDGMENT OF AMENDMENT**

Offerors must acknowledge receipt of this amendment in writing, by the date and time specified for proposal submissions or the revised Due Date above (if revised), whichever is later. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE DESIGNATED LOCATION BY THE SPECIFIED DATE AND TIME MAY RESULT IN REJECTION OF YOUR OFFER. If, by virtue of this amendment you wish to change your offer, such change must make reference to the solicitation and this amendment.

<b>NAME AND ADDRESS OF OFFEROR</b>          <b>OFFEROR</b> <i>(Signature of person authorized to sign)</i>	<b>NAME OF SIGNER</b>
	<b>TITLE OF SIGNER</b>
	<b>DATE</b>

1. Will CPCCo provide Data Sheets for instrumentation? **No contractor to submit data sheets as submittal and CPCCo will approve or provide comments.**
2. What are the Subcontractor provided FWS requirements for this RFP? **FWS support should be commensurate with the schedule of work. As mentioned in the walkdown, there are major**

scopes of work that will require oversight whether they are worked independent or together. Your schedule will dictate numbers of applicable supervision.

3. Will CPCCo provide a list of GFE/BFE for this RFP? **GFE provided by CPCCo is listing in SOW per Section 01019 1.2.1.**
4. Will data logger be required for single wall HDPE fusion bonds? **No.**
5. Will CPCCo please define the "associated equipment" needed to feed Air Stripper Tower C from CSIP-Y30E & CSIP-Y30F?  
**Pumps, SS piping, anchors, pipe supports, instrumentation, valves, connection to BPE line, etc. This list is not all inclusive. Flow control valve from CSIP and HDPE piping on back pad to AST influent header, along with related PVC mods, are not part of this scope of work.**
6. Will CPCCo please define the "associated equipment" to transfer water to ITB-1 & ITB-2 from ASEP-Y63E, ASEP-Y63F, ASEP-Y63G, and ASEP-Y63H? **Pumps, SS piping, anchors, pipe supports, instrumentation, heat trace and insulation, motor actuated valves and other valves, white iron mods, electrical rack fabrication and installation of electrical components and breaker upgrades, etc. This list is not all inclusive.**
7. Can CPCCo please clarify which components/equipment are to be priced under SOW Task 1.1.1? There seems to be some overlap with SOW Task 2.1.3. **Task 1, 1.1.1 is procurement for work regarding Air Stripper C, not to be confused with work listed in Task 2, 2.1.3 for 5 additional wells.**
8. Design deficiencies have been identified with regard to routing, dimensions and support details. Would subcontractor field routing be accepted by CPCCo? **Yes, with CPCCo engineering approval.**
9. What is material is the "liner" to be removed referenced in Tasks 2.4, 2.6, 2.9, 2.10, and 2.12? **Liner material is plastic.**
10. Please identify which filter housings and filters are required for ETB-1 and ETB-2 as there is a discrepancy between the SOW and SGW-54045, Revision 2. Please include up to date model numbers. **SUEZ HX0740-3.F-316-A.**
11. Please identify which filter housings and filters are required for 289T as there is a discrepancy between the SOW and SGW-54045, Revision 2. Please include up to date model numbers. **SUEZ HX0740-3.F-316-A.**
12. Have GFE/BFE pumps been maintained per manufacturers guidelines? **No.**
13. How many FWS will be provided by CPCCo? **Two Construction Managers, and One Field Work Supervisor will provide oversight of contractor Field Work Supervisors.**
14. How many concurrent work fronts may be performed per shift? **As many as necessary to meet the required performance dates.**

15. What coatings have been applied to power poles to be disposed? **Creosote, but per our Waste Management, CPCCo will dispose of any poles and associated waste that is not releasable.**
  
16. Please clarify what "white iron modifications" are to be made in accordance with ECR-19-001512. **Addition of two square braces and cross brace, modify column base plate, modify VOG pipe rack frame in support of cross brace attachment plates. See Page 15 of ECR-19-001512 for VOG pipe rack modifications.**
  
17. Where are materials/instrumentation/equipment costs for Optional Task 4 to be included on pricing sheets? Other tasks have material costs and labor costs separated.  
**Add in as separate line item or as a separate sheet. Detail that the costs are tied directly to Task 4 work.**
  
18. Please specify the supports to be installed under Task 1.2.2 as other tasks also reference installing supports. Which supports does CPCCo wish to see where on pricing sheet?  
**Supports as detailed in the task specific ECRs should be placed into the task specific pricing sheet, if the contractor is breaking out pricing by task. For example, the task 1.2.2 supports would be any additional supports for the new acid line, supports for the ASEP and CSIP piping, the VOG cross brace and white iron modifications, the two additional square steel supports, and supports for electrical racks/equipment. Please note that this list may not be all inclusive. Reference structural and mechanical drawings for support locations and callouts.**
  
19. Please specify the instrumentation to be installed under Task 1.2.4 as other tasks also reference installing instrumentation. Which instrumentation does CPCCo wish to see where on pricing sheet?  
**Instrumentation as detailed in the task specific ECRs should be placed into the task specific pricing sheet, if the contractor is breaking out pricing by task. For example, the task 1.2.4 instruments would be any instruments for the ASEP and CSIP pumps and instruments for the acid spool. Please note that this list may not be all inclusive. Reference mechanical and I&C drawings for instrument locations and callouts.**
  
20. In regards to Task 4: should the procurements for the materials associated with this work be included in with the procurement line for Task 1.1.1 or can an additional task 4.2 be included?  
**An amendment to task 4 in the subject RFP will be provided by CPCCo by COB on 9/18 to provide associated procurements. See attached SOW.**